


Testing Photomultiplier Tubes for nEXO's Outer Detector

2024 CASST Competition
Lazar Paroski
Queen's University
August 19 2024


Outline

- Introduction to $0\nu\beta\beta$ and nEXO
- Designing the PMT testing Setup Cooling Loop
 - Intro to the PMT Testing Setup
 - Initial Design Ideas
 - Calculations
 - Bill of Materials and Concerns
 - Improved Design
 - Calculations
 - Final Bill of Materials
- Future Setup
 - Design
 - Calculations
 - Bill of Materials
- Data Analysis Script Improvements
 - Data Management Improvements
 - FFT and Peak Isolation Stress Test
- Conclusion


$2\nu\beta\beta$ vs $0\nu\beta\beta$



$0\nu\beta\beta$ signature is peak at nucleus Q value




$2\nu\beta\beta$ spectrum measured in ^{136}Xe with EXO-200!



nEXO Experiment


- 5-tonne single-phase liquid Xenon Time Projection Chamber (TPC)
- Enriched to 90% in isotope ^{136}Xe
- OD used for passive and active shielding
- Target half-life sensitivity of $1.35 \cdot 10^{28}$ years



Source:
<https://nexo.llnl.gov/nexo-overview>

nEXO Outer Detector (OD)


- Passive and active shielding
- Q value for $0\nu\beta\beta$ $^{136}\text{Xe} \rightarrow ^{136}\text{Ba}$ is **2458 keV** [1]
- Muons passing through TPC can create neutrons that can create energy signatures around Q value :(
- OD is veto for TPC by detecting Cherenkov radiation :(



[1] Search for double-beta decay of ^{136}Xe to excited states of ^{136}Ba with the KamLAND-Zen experiment
<https://arxiv.org/pdf/1509.03724>

The PMT Testing Setup

- Located at Laurentian University
- PMT attached to barrel lid
- Barrel lid in dark enclosure
- This will help learn for future setups





The PMT Testing Setup

- Barrel needs a way to change and keep stable temperature
- OD will be held at 12°C
- PolyScience AP15R-40-A11B refrigerated circulator



Design Ideas

- Coil Inside Barrel
- Coil Outside Barrel
- Each setup has some pros/cons
- I updated CAD models in Fusion 360



Calculations — Simple

Time to cool barrel from 25 °C to 10 °C,

P = 956 W (Cooling Capacity at 17.5 °C)

Time with no heat leaking in barrel :

$$Q = mc\Delta T \quad t = \frac{Q}{P}$$

t = 4.07 Hours

Time with Insulation with an R-Value of 2:

$$\frac{dQ}{dt} = U \cdot A \cdot \Delta T = \frac{1}{R} \cdot A \cdot \Delta T$$


t = 4.14 Hours

Calculations — Coil in Barrel

$$\frac{d}{dt}Q = U \cdot A \cdot \Delta T \quad A = 0.0127 \cdot \pi \cdot L$$


1. $dQ/dt < 956 \text{ W}$ – Area of coil is bottleneck cooling
2. $dQ/dt = 956 \text{ W}$ – Coil exchanges heat at the same rate as the cooler:
L = 4m
3. $dQ/dt > 956 \text{ W}$ – Making coil longer has no cooling benefits

Will Cool in 4.14 Hours if more than 4m of tubing is used



Calculations — Coil Outside of Barrel

Time to Cool Barrel from 25°C to 15°C with Respect to Coil Length and Insulation with an R Value of 2




$$A = L \cdot 0.002$$

- Too Long to cool
- Don't want to use more than 15m of coil

Bill of Materials

- Still concerns with setup
- Coil in barrel could interfere with detection
- Setup has additional Issues...




DESIGN A						
Material	Link	Quantity	Supplier	Part Number	Cost/Unit (USD)	Total (USD)
Section 1						
Barbed Fitting	https://www.mcmaster.com/5357K39/	2	McMaster-CARR	5357K39	\$ 5.36	\$ 10.72
Hose Clamp (10 pack)	https://www.mcmaster.com/5415K33/	1	McMaster-CARR	5415K33	\$ 11.84	\$ 11.84
Section 2						
Soft PVC Tubing (50 ft)	https://www.mcmaster.com/5231K89/	1	McMaster-CARR	5231K89	\$ 69.00	\$ 69.00
Soft PVC Tubing Insulation (6 ft)	https://www.mcmaster.com/44745K23/	7	McMaster-CARR	44745K23	\$ 11.72	\$ 82.04
Section 3						
Through Wall Connector	https://www.mcmaster.com/6696K58/	2	McMaster-CARR	6696K58	\$ 126.86	\$ 253.72
NPT (Male) X NPT (Male) connector	https://www.mcmaster.com/44665K151/	4	McMaster-CARR	44665K151	\$ 3.47	\$ 13.88
Barbed Fitting (5 pack)	https://www.mcmaster.com/5346K38/	1	McMaster-CARR	5346K38	\$ 16.92	\$ 16.92
Section 4						
Through Wall Connector	https://www.mcmaster.com/6696K58/	2	McMaster-CARR	6696K58	\$ 126.86	\$ 253.72
Quick Connect Body (NPT Male) (IN CAD)	atersystems.com/products/lq6d10006blu-valved-pipe-thread	4	Fresh Water Systems	LQ6D10006BLU	\$ 104.00	\$ 416.00
Quick Connect Stem (Barbed) (IN CAD)	atersystems.com/products/lq6d22006blu-valved-in-line	2	Fresh Water Systems	LQ6D22006BLU	\$ 73.00	\$ 146.00
Quick Connect Stem (NPT Male) (IN CAD)	https://www.usplast.com/catalog/item.aspx?itemid=102531	2	USP	LQ6D24006BLU	\$ 115.88	\$ 231.76
Push-to-Connect to NPT Female	https://www.mcmaster.com/5483K47/	2	McMaster-CARR	5483K37	\$ 7.99	\$ 15.98
Section 5						
Barrel Insulation	https://www.mcmaster.com/9349K9/	8	McMaster-CARR	9349K9	\$ 30.67	\$ 245.36
Copper Tubing (50 ft)	https://www.mcmaster.com/5174K24-5174K6/	1	McMaster-CARR	5174K24	\$ 159.91	\$ 159.91

If we want to use Swagelock quick connects it is an extra \$1000 USD on top of the current subtotal

Subtotal (USD) \$ 1,926.85

Quick Connect Concerns

Flow Rate vs Pressure for QTM2 and QTM4 Quick Connects




Cooler max Pressure: 4.35 Psi

Cooler max Flow Rate: 20.1 lpm


$$q = N_1 C_v \sqrt{\frac{\Delta p}{G}}$$

Series	Spillage cm ³
QTM2	0.1
QTM4	0.2
QTM8	1.0



Improved Design

- TRACIT-1100 heat transfer compound
- Heat transfer coefficient: 114-227 W/m²*K
- Relatively inexpensive solution
- Avoids quick connect flow and spillage issues
- Avoids coil interfering with detection issues



Calculations


- Used thermal resistance
- Putty buffer is amount of putty on either side of tubing
- Cooling time reasonable making this option feasible

Heat Transfer Coefficient	Area
$U_{\text{copper-putty}} = 114 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{cp}} = 0.0127 \cdot \pi \cdot L$
$U_{\text{steel-water}} = 400 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{sw}} = L \cdot 2 \cdot B$
$U_{\text{putty-steel}} = 114 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{ps}} = L \cdot 2 \cdot B$

$$R_{\text{tot}} = \sum \frac{1}{U \cdot A}$$

$$\frac{dQ}{dt} = \frac{\Delta T}{R_{\text{tot}}}$$


Hours to Cool the Barrel from 25°C to 10°C with Respect to Putty Buffer and Coil Length with Insulation with an R Value of 2



$$t = \frac{14 \cdot 10^6}{3600 \left(\frac{15}{\frac{1}{114 \cdot 0.0127 \cdot \pi \cdot L} + \frac{1}{400 \cdot 2 \cdot B \cdot L} + \frac{1}{114 \cdot 2 \cdot B \cdot L}} - 17 \right)}$$

Final Bill of Materials

- Avoids issues with previous set up by putting coil outside of barrel
- BOM is ordered




Name	Description	Link	Quantity	Supplier	Part Number	Cost/Unit (USD)	Total (USD)	Image	Diagram Letter	
Section 1										
Barbed Fitting	Aluminum, Hose ID 1/2", 1/4" NPT Male	https://www.mcma-ster.com/5357K39/	2	McMaster-CARR	5357K39	\$ 5.36	\$ 10.72		A	
Hose Clamps	5/8"-15/16"	https://www.mcma-ster.com/45945K63/	10	McMaster-CARR	45945K63	\$ 6.47	\$ 64.70		B	
Section 2										
Soft PVC Tubing	25 ft/unit, ID 1/2", OD 3/4"	https://www.mcma-ster.com/5231K89/	1	McMaster-CARR	5231K89	\$ 34.50	\$ 34.50		A	
Tubing Insulation	6 ft/unit, R value 2	https://www.mcma-ster.com/44745K23/	4	McMaster-CARR	44745K23	\$ 11.72	\$ 46.88		B	
Cable Holder	Fit up to 3 1/4" Diameter	https://www.mcma-ster.com/6912K65/	5	McMaster-CARR	6912K45	\$ 7.80	\$ 39.00		C	
Section 3										
Through Wall Connector	3/8" NPT Female, Stainless Steel	https://www.mcma-ster.com/6696K58/	2	McMaster-CARR	6696K58	\$ 126.86	\$ 253.72		A	
Barbed Fitting	Aluminum, Hose ID 1/2", 3/8" NPT Male	https://www.mcma-ster.com/5357K41/	4	McMaster-CARR	5357K41	\$ 5.64	\$ 22.56		B	
Section 4										
Brass Push-to-Connect Fitting	For 3/8" tube ID and 1/2" tube OD, 1/2" NPT Male	https://www.mcma-ster.com/5483K47/	2	McMaster-CARR	5483K47	\$ 7.99	\$ 15.98		A	
NPT Female Barbed Fitting	Hose ID 1/2", 1/2" NPT Female, Brass	https://www.mcma-ster.com/5346K57/	2	McMaster-CARR	5346K57	\$ 4.33	\$ 8.66		B	
Section 5										
Copper Tubing	ID 3/8", OD 1/2", 50 ft/unit	https://www.mcma-ster.com/5174K24-5174K6/	1	McMaster-CARR	5174K24	\$ 159.91	\$ 159.91		A	
Heat-Transfer Putty	1 Gallon, Look at SDS for more info	https://www.mcma-ster.com/3568K43/	2	McMaster-CARR	3568K43	\$ 98.33	\$ 196.66		B	
Instant-Bonding Adhesive	2 FL. oz /container	https://www.mcma-ster.com/7605A13/	1	McMaster-CARR	7605A13	\$ 7.87	\$ 7.87		C	
Tube Clamps (Price is CAD)	Copper, 10 Clamps/ Bag	https://www.homedepot.ca/product/dghl-1-2-tube-	2	The Home Depot	1000148597	\$ 6.70	\$ 13.40		D	
Section 6										
Bubble Sheet	48"x25 ft, For all insulation, 4.2 R value	https://www.mcma-ster.com/9367K21/	1	McMaster-CARR	9367K21	\$ 79.37	\$ 79.37		A	
Fiberglass Insulation	48"x10 ft, For sides, 3.8 R value	https://www.mcma-ster.com/9346K11/	1	McMaster-CARR	9346K11	\$ 25.16	\$ 25.16		B	
Hard Foam Insulation	4 Feet x 48", 1" Thick, 5 R value	https://www.mcma-ster.com/9255K11/	1	McMaster-CARR	9255K11	\$ 49.58	\$ 49.58		C	
Soft Foam Insulation	4 Feet Long, 2 R value	https://www.mcma-ster.com/9326K46/	1	McMaster-CARR	9326K46	\$ 25.20	\$ 25.20		D	
Bags	For fiberglass insulation, 55"x45"x85"	https://www.mcma-ster.com/1066T22/	2	McMaster-CARR	1066T22	\$ 4.61	\$ 9.22		E	
Other										
Paper Towel	Paper, 12 Rolls/ Pack	https://www.mcma-ster.com/4501T202/	1	McMaster-CARR	4501T202	\$ 53.57	\$ 53.57			
Pipe Cutter Blade	Steel	https://www.mcma-ster.com/2757A21/	1	McMaster-CARR	2757A21	\$ 2.59	\$ 2.59			
							Total (USD pre tax)	\$ 1,144.41		

Design

- Same as successful barrel design
- Heat transfer putty will be used, and coil is outside pressure vessel
- I made CAD model for PV from scratch in Fusion


360



Calculations

- Fast cooling time
- Can use less coil for PV due to this
- This is good for space reasons since PV is smaller than barrel

Hours to Cool the PV from 25°C to 10°C with Respect to Putty Buffer and Coil Length with Insulation with an R Value of 2




Heat Transfer Coefficient or Thermal Conductivity	Area
$U_{\text{copper-putty}} = 114 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{cp}} = 0.0127 \cdot \pi \cdot L$
$U_{\text{steel-water}} = 400 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{sw}} = L \cdot 2 \cdot B$
$U_{\text{putty-steel}} = 114 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{ps}} = L \cdot 2 \cdot B$
$K_{\text{wall}} = 45 \text{ W}/(\text{m} \cdot \text{K})$	$A_{\text{w}} = L \cdot 2 \cdot B$

$$R = \frac{d}{k \cdot A} = \frac{1}{U \cdot A}$$

$$t = \frac{53 \cdot 10^5}{3600 \left(\left(\frac{15}{\frac{0.025}{45 \cdot L \cdot 2B} + \frac{1}{114 \cdot 0.0127 \cdot \pi \cdot L} + \frac{1}{114 \cdot 2B \cdot L} + \frac{1}{400 \cdot 2B \cdot L}} \right) - 17 \right)}$$

Bill of Materials


- Very affordable BOM
- Can reuse parts from barrel setup



Name	Description	Link	Quantity	Supplier	Part Number	Cost/Unit (USD)	Total (USD)	Image	Diagram Letter	
Section 1										
Brass Push-to-Connect Fitting	For 3/8" tube ID and 1/2" tube OD, 1/2" NPT Male	https://www.mcmaster.com/5483K47/	2	McMaster-CARR	5483K47	\$ 7.99	\$ 15.98		A	
NPT Female Barbed Fitting	Hose ID 1/2", 1/2" NPT Female, Brass	https://www.mcmaster.com/5346K57/	2	McMaster-CARR	5346K57	\$ 4.33	\$ 8.66		B	
Hose Clamps	10 pack, 5/8"-1 1/16"	https://www.mcmaster.com/5076K43/	1	McMaster-CARR	5076K43	\$ 12.23	\$ 12.23		C	
Section 2										
Heat-Transfer Putty	1 Gallon, Look at SDS for more info	https://www.mcmaster.com/3568K43/	1	McMaster-CARR	3568K43	\$ 98.33	\$ 98.33		A	
Tube Clamps (COST IN CAD)	10 Clamps /pack, For 1/2" OD tube, Copper	edepot.ca/product/dahl-1-2-tube-clamps-solid-copper	1	The Home Depot Canada	1000148597	\$ 6.70	\$ 6.70		B	
Copper Tubing	ID 3/8", OD 1/2", 50 ft/unit	https://www.mcmaster.com/5174K24-5174K6/	1	McMaster-CARR	5174K24	\$ 159.91	\$ 159.91		C	
Instant-Bonding Adhesive	0.9 FL. oz /container	https://www.mcmaster.com/5551T73/	3	McMaster-CARR	5551T73	\$ 9.43	\$ 28.29		D	
Section 3										
Bubble Sheet Insulation	48"x25 ft, For all sides, 4.2 R value	https://www.mcmaster.com/9367K21/	1	McMaster-CARR	9367K21	\$ 79.37	\$ 79.37		A	
Fiberglass Insulation	48"x10 ft, For sides, 3.8 R value	https://www.mcmaster.com/9346K11/	1	McMaster-CARR	9346K11	\$ 25.16	\$ 25.16		B	
Bags	For fiberglass insulation, 55"x45"x85"	https://www.mcmaster.com/1066T22/	2	McMaster-CARR	1066T22	\$ 4.61	\$ 9.22		C	
							Total (USD pre tax)	\$ 443.85		



How the Code Works

- The oscilloscope captures chunks of PMT data
- FFT is applied to convert the data to the frequency domain for filtering
- Inverse FFT brings it back to time domain
- Peak detection marks the start and end of peaks based on set amplitude thresholds
- I made a script that lets me analyze what is happening visually





Issue Found through Testing

- Code is marking peaks that are too small as signals
- Easy fix!
- Can adjust thresholds for peak detection to > -0.0005 V (peaks are negative)
- Can verify if it works with visualization code I made



Improvement Results

- Quick fix, but important issue to discover
- Would have had incorrect dark rate



Conclusion

- Designed multiple potential cooling systems
- Made CAD models for the various setups
- Did calculations to identify the best approach
- Made bills of materials for multiple designs and ordered parts for the final design
- Did the above for the future testing setup (Pressure Vessel)
- Made improvements to how data is managed for data analysis
- Stress tested FFT and peak isolation scripts and made improvements

Acknowledgements

Thank you to:



- Dr. Erica Caden
- Anita Masuskapoe
- Dr. Ubi Wichoski
- SNOLAB and the nEXO collaboration for making this great summer possible!



Backups

Double Beta Decay – $2\nu\beta\beta$

- $2\nu\beta\beta$ decay is rare
- Candidate isotopes: even-even nuclei where single β decay is forbidden
- Observed in 14 isotopes



Source: <https://arxiv.org/pdf/1109.5515>


Isotopes that can Undergo $2\nu\beta\beta$

Nuclide	Half-life, 10^{21} years	Mode	Transition	Method	Experiment
^{48}Ca	$0.064^{+0.007}_{-0.006} \pm ^{+0.012}_{-0.009}$	$\beta\beta^-$		direct	NEMO-3 ^[11]
^{76}Ge	1.926 ± 0.094	$\beta\beta^-$		direct	GERDA ^[10]
^{78}Kr	$9.2^{+5.5}_{-2.6} \pm 1.3$	$\epsilon\epsilon$		direct	BAKSAN ^[10]
^{82}Se	$0.096 \pm 0.003 \pm 0.010$	$\beta\beta^-$		direct	NEMO-3 ^[10]
^{96}Zr	$0.0235 \pm 0.0014 \pm 0.0016$	$\beta\beta^-$		direct	NEMO-3 ^[10]
^{100}Mo	0.00693 ± 0.00004	$\beta\beta^-$		direct	NEMO-3 ^[10]
	$0.69^{+0.10}_{-0.08} \pm 0.07$	$\beta\beta^-$	$0^+ \rightarrow 0^+_1$		Ge coincidence ^[10]
^{116}Cd	$0.028 \pm 0.001 \pm 0.003$	$\beta\beta^-$		direct	NEMO-3 ^[10]
	$0.026^{+0.009}_{-0.005}$				ELEGANT IV ^[10]
^{128}Te	7200 ± 400 1800 ± 700	$\beta\beta^-$		geochemical	[10]
^{130}Te	$0.82 \pm 0.02 \pm 0.06$	$\beta\beta^-$		direct	CUORE-0 ^[12]
^{124}Xe	$18 \pm 5 \pm 1$	$\epsilon\epsilon$		direct	XENON1T ^[13]
^{136}Xe	$2.165 \pm 0.016 \pm 0.059$	$\beta\beta^-$		direct	EXO-200 ^[10]
^{130}Ba	$(0.5 - 2.7)$	$\epsilon\epsilon$		geochemical	[14][15]
^{150}Nd	$0.00911^{+0.00025}_{-0.00022} \pm 0.00063$	$\beta\beta^-$		direct	NEMO-3 ^[10]
	$0.107^{+0.046}_{-0.026}$	$\beta\beta^-$	$0^+ \rightarrow 0^+_1$		Ge coincidence ^[10]
^{238}U	2.0 ± 0.6	$\beta\beta^-$		radiochemical	[10]

Linear Interpolation for Cooling Capacity

- Most Calculations Look at cooling time from 25 °C to 10 °C
- Middle is 17.5 °C
- Cooling Capacity at 20 °C is 1000 W and at 0 °C is 650 W

Average Cooling Capacity is:
956 W



Calculations - Simple

Time to cool from 25 °C to 10 °C

Simple Calculation Perfect Insulation:

$$55\text{GAL} \cdot \frac{3.78\text{L}}{\text{GAL}} + 15\text{L} = 208\text{L} + 15\text{L} = 223\text{L}$$

$$Q = mc\Delta T = 223\text{ kg} \cdot 4184 \frac{\text{J}}{\text{kg}^\circ\text{C}} \cdot 15^\circ\text{C} = 14 \cdot 10^6 \text{ J}$$

Coolers Max Cooling Capacity is **956 W**

$$t = \frac{Q}{P} = \frac{14 \cdot 10^6 \text{ J}}{956 \frac{\text{J}}{\text{s}}} \cdot \frac{1 \text{ h}}{3600 \text{ s}} \approx \boxed{4.07 \text{ hours}}$$

Simple Calculation with R-Value 2 Insulation:

$$\frac{dQ}{dt} = U \cdot A \cdot \Delta T = \frac{1}{R} \cdot A \cdot \Delta T$$

$$\frac{dQ}{dt} = \frac{1}{2 \text{ m}^2\text{K}} \cdot 2.27 \text{ m}^2 \cdot 15 \text{ K} = 17.0 \text{ W}$$

$$956 \text{ W} - 17 \text{ W} = 939 \text{ W}$$

$$t = \frac{Q}{P} = \frac{14 \cdot 10^6 \text{ J}}{939 \frac{\text{J}}{\text{s}}} \cdot \frac{1 \text{ h}}{3600 \text{ s}} \approx \boxed{4.14 \text{ hours}}$$

Calculations — Coil in Barrel

$$\frac{d}{dt}Q = U \cdot A \cdot \Delta T$$

Cooling Capacity depends only on A. This gives 3 cases for dQ/dt that only depend on A:

1. $dQ/dt < 956 \text{ W}$ – Area of coil is bottleneck cooling
2. $dQ/dt = 956 \text{ W}$ – Coil exchanges heat at the same rate as the cooler
3. $dQ/dt > 956 \text{ W}$ – Making coil longer has no cooling benefits

$$A = 0.0127 \cdot \pi \cdot L$$

$$\frac{d}{dt}Q = U \cdot 0.0127 \cdot \pi \cdot L \cdot \Delta T$$

$$L = \frac{\frac{d}{dt}Q}{U \cdot 0.0127 \cdot \pi \cdot \Delta T}$$

$$L = \frac{956 \text{ W}}{400 \frac{\text{W}}{\text{m}^2\text{K}} \cdot 0.0127 \text{ m} \cdot \pi \cdot 15 \text{ K}} = 4 \text{ m}$$

Increasing coil length past 4m has no benefits

Calculations – Coil Outside of Barrel


$$A = L \cdot 0.002$$

$$\frac{d}{dt}Q = 400 \frac{\text{W}}{\text{m}^2\text{K}} \cdot (0.002 \cdot L) \text{m}^2 \cdot 15 \text{K}$$

$$t = \frac{14 \cdot 10^6}{3600 \left(\frac{dQ}{dt} - 17\text{W} \right)}$$

$$t = \frac{14 \cdot 10^6}{3600 \cdot (400 \cdot 0.002 \cdot L \cdot 15 - 17)}$$

Time to Cool Barrel from 25°C to 15°C with Respect to Coil Length and Insulation with an R Value of 2



Quick Connect Concerns




Series	Spillage cm ³
QTM2	0.1
QTM4	0.2
QTM8	1.0

$$q = N_1 C_v \sqrt{\frac{\Delta p}{G}}$$

$$q_{QTM2} = 3.7854 \cdot 0.8 \sqrt{\frac{4.35}{1}} = 6.32 \text{ lpm}$$

$$q_{QTM4} = 3.7854 \cdot 1.6 \sqrt{\frac{4.35}{1}} = 12.63 \text{ lpm}$$



Calculations Outside Barrel Final

$$R_{tot} = \sum \frac{1}{U \cdot A}$$

$$\frac{dQ}{dt} = \frac{\Delta T}{R_{tot}}$$

Heat Transfer Coefficient	Area
$U_{\text{copper-putty}} = 114 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{cp}} = 0.0127 \cdot \pi \cdot L$
$U_{\text{steel-water}} = 400 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{sw}} = L \cdot 2 \cdot B$
$U_{\text{putty-steel}} = 114 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{ps}} = L \cdot 2 \cdot B$

$$\frac{dQ}{dt} = \frac{15}{\frac{1}{114 \cdot 0.0127 \cdot \pi \cdot L} + \frac{1}{400 \cdot 2 \cdot B \cdot L} + \frac{1}{114 \cdot 2 \cdot B \cdot L}}$$

$$t = \frac{14 \cdot 10^6}{3600 \left(\frac{dQ}{dt} - 17\text{W} \right)}$$

$$t = \frac{14 \cdot 10^6}{3600 \left(\frac{15}{\frac{1}{114 \cdot 0.0127 \cdot \pi \cdot L} + \frac{1}{400 \cdot 2 \cdot B \cdot L} + \frac{1}{114 \cdot 2 \cdot B \cdot L}} - 17 \right)}$$

Calculations PV

$$Q = mc\Delta T = 84.28 \text{ kg} \cdot 4181 \frac{\text{J}}{\text{kg}^\circ\text{C}} \cdot 15^\circ\text{C}$$

$$Q = 53 \cdot 10^5 \text{ J}$$

$$t = \frac{53 \cdot 10^5}{939 \cdot 3600} = \boxed{1.57 \text{ hours}}$$

Heat Transfer Coefficient or Thermal Conductivity	Area
$U_{\text{copper-putty}} = 114 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{cp}} = 0.0127 \cdot \pi \cdot L$
$U_{\text{steel-water}} = 400 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{sw}} = L \cdot 2 \cdot B$
$U_{\text{putty-steel}} = 114 \text{ W}/(\text{m}^2 \cdot \text{K})$	$A_{\text{ps}} = L \cdot 2 \cdot B$
$K_{\text{wall}} = 45 \text{ W}/(\text{m} \cdot \text{K})$	$A_{\text{w}} = L \cdot 2 \cdot B$

$$R_{\text{tot}} = \frac{d_{\text{w}}}{k_{\text{w}} \cdot A_{\text{w}}} + \frac{1}{U_{\text{cp}} \cdot A_{\text{cp}}} + \frac{1}{U_{\text{ps}} \cdot A_{\text{ps}}} + \frac{1}{U_{\text{sw}} \cdot A_{\text{sw}}}$$

$$t = \frac{53 \cdot 10^5}{3600 \left(\left(\frac{15}{\frac{0.025}{45 \cdot L \cdot 2B} + \frac{1}{114 \cdot 0.0127 \cdot \pi \cdot L} + \frac{1}{114 \cdot 2B \cdot L} + \frac{1}{400 \cdot 2B \cdot L}} \right) - 17 \right)}$$


Time for Exterior to Heat Barrel by 1 °C wrt R-Value

$$Q = mc\Delta T = 223.175 \text{ kg} \cdot 4181 \frac{\text{J}}{\text{kg}^\circ\text{C}} \cdot 1^\circ\text{C}$$

$$Q = 93.3 \cdot 10^4 \text{ J}$$


$$t = \frac{Q}{\frac{d}{dt}Q} = \frac{93.3 \cdot 10^4}{86400 \cdot 2.27 \cdot 10} R = \frac{93.3}{196} R$$

Time to Heat Barrel that is 10°C colder than Surroundings by 1°C with Respect to R-Value of Insulation




Data Management Improvements

PMT_Data_Folder



Having to hard code file and folder names every time you change something.

Data Management Improvements



Only having to put things in the right folder when you change something.

Data File Example

```
1 > pmt-1560_noise_closed_loff-2023-11-23 > C2pmt-1560-noise-000000.txt
1  LECROYWS3054z,46730,Waveform
2  Segments,1,SegmentSize,10000002
3  Segment,TrigTime,TimeSinceSegment1
4  #1,23-Nov-2023 14:47:51,0
5  Time,Ampl
6  -0.005000000467,0.00026666667
7  -0.004999999467,0.00026666667
8  -0.004999998467,0.0002
9  -0.004999997467,0.0002
10 -0.004999996467,0.00026666667
11 -0.004999995467,0.00026666667
12 -0.004999994467,0.00026666667
13 -0.004999993467,0.00026666667
14 -0.004999992467,0.00033333333
15 -0.004999991467,0.00033333333
16 -0.004999990467,0.00033333333
17 -0.004999989467,0.00026666667
18 -0.004999988467,0.0002
19 -0.004999987467,0.0002
20 -0.004999986467,0.00026666667
21 -0.004999985467,0.00026666667
22 -0.004999984467,0.00026666667
23 -0.004999983467,0.00026666667
24 -0.004999982467,0.00026666667
25 -0.004999981467,0.00033333333
26 -0.004999980467,0.00026666667
27 -0.004999979467,0.00026666667
28 -0.004999978467,0.0002
29 -0.004999977467,0.0002
30 -0.004999976467,0.0002
31 -0.004999975467,0.00026666667
32 -0.004999974467,0.00026666667
33 -0.004999973467,0.00026666667
34 -0.004999972467,0.00026666667
35 -0.004999971467,0.00026666667
36 -0.004999970467,0.00026666667
37 -0.004999969467,0.0002
```